



SECTION A-A
PROBE ALIGNMENT
SLOT REQUIRED FOR
ALL BARS.

NOTES:

1. INSTALL IN ACCORDANCE WITH AIRFLOW DIRECTION INDICATOR.
2. FOR QTY. OF PROBES & SENSORS PER PROBE SEE SCHEDULE.
3. FOR SINGLE BAR UNITS USE PROBE 1 ASS'Y ONLY. FOR UNITS WITH TWO BARS USE PROBE ASS'Y 1 & 2.

INSULATION REQUIREMENTS		
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
NONE	0.5 INCH	1 INCH

SELECTION OF MATERIALS FOR CONSTRUCTION			
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
ALUMINUM & ABS	CPVC & ABS	304 STAINLESS STEEL	HIGH. TEMP STEEL



ENGINEERING DEPARTMENT
41 EAGLE ROAD
DANBURY, CT 06810
(203) 791-1400 PHONE
(203) 798-6534 FAX

VORTEK 2100
AIRFLOW MEASURING DEVICES

INSTALLATION DRAWING
CIRCULAR DUCT INSERTION PROBE

REVISION:		DWG NO.:
REVISION DATE:		DRAWN BY:
FILENAME:VT2100-2X2.VSD		JOB NO.: