



## Mounting & Tubing Detail



## Wiring Detail



### Notes:

- External 24 VAC By Others.
- Cabinet Description:  
Rating: Nema 1  
Construction: 18 ga. CRS.  
Paint: Blue Enamel
- 50 ft. Maximum Total Tube Length.



Engineering Department  
41 Eagle Road  
Danbury, CT 06810  
(203) 791-1400 Phone  
(203) 798-6534 Fax

**ISO-TEK**  
Pressurization Monitor for  
Isolation Rooms and Labs

Transmitter Drawing

Revision Letter: A

Index No: 11-1

Revision Date: 11/22/95

Drawn By: RBC

Filename: ISO-TRAN.CDR

Job No.: